

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2018/SZ / 259

Dated: 15/02/18

FIRE SAFETY CERTIFICATE

Certified that the Hari Krishna Public School, A-114-118, Mansa Ram Park, Uttam Nagar, New Delhi-110059, having total 22 rooms on ground floor & first floor (including class rooms & office etc.) owned/occupied by Hari Krishna Public School was issued NOC for Ground plus one upper floor by this department vide letter no. No F.6/DFS/MS/2006/2796 dated 25.09.06. The school was re-inspected by the officer concerned of this department on 09.01.2018 in the presence of Sh. Ashok Sharma (Manager). The Hari Krishna Public School comprised of ground plus one upper floor of a four storied building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises (Ground plus one upper floor-only) is fit for occupancy class "Educational" for a period of three years, subject to compliance of the conditions printed as under.

Issued on.....15/02/18..... at New Delhi.

Ventat
(VIPIN KENTAL)
CHIEF FIRE OFFICER

Copy to:-

1. The Manager,
Hari Krishna Public School, A-114-118,
Mansa Ram Park, Uttam Nagar, New Delhi-110059
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations in construction shall be verified by the concerned building sanctioning authority.
6. The deficiencies may not be treated in any case for the regularization of the unauthorized construction, if

Hari Krishna Public School
Mansa Ram Park, Uttam Nagar, New Delhi-110059
Affiliated to CBSE

A-114-118, Mansa Ram Park, Uttam Nagar, New Delhi-110059